



(317) 392-5131

\*

Fax (317) 392-5132

Office of the  
Water Resource Recovery Facility  
Superintendent  
Kevin Kredit

### INDUSTRY DISCHARGE LIMITS

Biochemical Oxygen Demand 200 Mg/L

pH 5.0 - 10.0

Oil & Grease 100 Mg/L or 25 Mg/L soluble oil

Suspended Solids 250 Mg/L

Arsenic	1.0 Mg/L	Cadmium	1.0 Mg/L	Copper	4.0 Mg/L
Cyanide	1.0 Mg/L	Lead	1.0 Mg/L	Mercury	0.10 Mg/L
Nickel	4.0 Mg/L	Hex. Chrom.	2.5 Mg/L	Tot. Chrom.	5.0 Mg/L
Zinc	4.0 Mg/L	Silver	1.0 Mg/L	PCB's	None
Phenol	10.0 Mg/L	Ammonia	20.0 Mg/L		

### WATER RESOURCE RECOVERY DISCHARGE LIMITS

Effluent Characteristic		Lbs./day	Lbs./day	Monthly Average	Weekly Average
		Monthly Average	Weekly Average		
C.B.O.D.	Summer *	1335	2003	20 Mg/L	30 Mg/L
	Winter **	1669	2670	25 Mg/L	40 Mg/L
T.S.S.	Summer *	1602	2403	24 Mg/L	36 Mg/L
	Winter **	2003	3004	30 Mg/L	45 Mg/L
Ammonia, as N	Summer *	227	340	3.4 Mg/L	5.1 Mg/L
	Winter **	354	534	5.3 Mg/L	8.0 Mg/L
Phosphorus	Interim	---	---	Report	
	Final	---	---	1.0 Mg/L	
E-Coli	125/100ml Mth. Avg.	235/100ml Daily Max.		April - October	
pH	6.0 Daily Minimum		9.0 Daily Maximum		
Dissolved Oxygen	Daily Minimum 4.0 Mg/L				

\* Summer limitations apply from May through November 30 each year.

\*\* Winter limitations apply from December 1 through April 30 each year.

PLANT DESIGN: 8.0 MGD with 16.0 MGD daily peak.

2019 AVERAGE FLOW: 5.4 MGD